



SILENT KNIGHT

by Honeywell

ECS-125WBD/125WHVBD* board only Installation Instructions

This Installation sheet will provide information on how to install the ECS-125WBD

Note: Installation and wiring of this device must be done in accordance with NFPA 72 and local ordinances. For more information see ECS-Series installation manual PN 151455.

*Note: *All references to ECS-125WBD within this sheet are applicable to ECS-125WHVBD*

Mounting the ECS-125WBD

1. Make certain that AC and DC power have been removed from the panel.
2. If this module is a replacement for an existing ECS-125W, remove the screws which secure the board to the enclosure.
3. Secure the supplied bracket to the top mounting bracket on the ECS-125WBD with the two mounting screws. See Figure 1.




Figure 1: ECS-125WBD mounting bracket

4. Align the mounting holes on the bracket with the enclosure.
5. Secure the board to the enclosure.
6. Restore AC power and reconnect the backup batteries.




Figure 2: ECS-125WBD in enclosure



SILENT KNIGHT

by Honeywell

12 Clintonville Road
Northford, CT 06472-1610 USA
203-484-7161
Fax: 203-484-7118
www.silentknight.com

© 2012 Honeywell International Inc.

P/N LS10003-001SK-E Rev B
ECN 12-0084