



**SILENT
KNIGHT**

by Honeywell

12 Clintonville Road
Northford, CT 06472-1610 USA
203-484-7161
Fax 203-484-7118
www.silentknight.com


© 2010 Honeywell International Inc.

LS10052-001SK-E Rev A DOC,WIRING DIAGRAM,IFP-2000ECS/HV – Page 1 of 3

Notes:



1. Printed on 8.5 x 14" paper. OK to print front to back
2. Shall be printed black lettering on white background
3. Document is folded & placed in pouch on cabinet cover

Used on: IFP-2000ECS, IFP-2000ECSHV, IFP-2000ECSCB



240V (IFP-2000ECSHV)

120V (IFP-2000ECS)



Flexput™ Circuits
Style B or Style A
Supervised

All circuits inherently power limited except AC input, phone line and battery leads.

Silent Knight SLK-24F 2-wire detector with HSB-224 base

2-Wire Smoke Requirements
See Installation Manual for UL listed smoke detectors. UL requirements do not permit mixing of detectors on any system. Compatibility Identifier 24N

Electrical Specifications

Terminal	Function	Current	Voltage
W & B	AC Input (Hot and Neutral)	5A 2.5A	120VAC, 50Hz 240VAC, 60 Hz
G	Earth Ground	N/A	N/A
I/O1 - I/O8	*Notification Circuits	3.0 A or 9.0A max total 100mA for Initiating Circuit	24 VDC
SBUS A B	SBUS communication	100 mA	5 VDC
SBUS - +	SBUS Power	1.0 A	24 VDC
Trouble, Relay1, Relay 2	Relay circuits	2.5 A	24 VDC
SLC OUT-SLC IN	SLC terminals	150 mA	32 VDC
**Battery Leads	Charging current	1.12 A	24 VDC
Ring Tip Telco	Phone line inputs	N/A	N/A
Ring Tip Phone	Phone line inputs	N/A	N/A
I/O1-I/O8	Notification circuits		3 V
I/O1 - I/O8	Notification circuits		Panel wide regulated
Ground Fault Impedance to any Terminal	Sync Output/Circuit Type		0Ω

* Regulated/Special application. See Installation Manual for details.
**Replace Batteries Every 5 years.

For Releasing Service See Installation Manual
For Battery Capacity see Installation Manual

This control panel is equipped with JumpStart® auto-programming feature which can greatly reduce system setup time.

JumpStart is intended to be used prior to any custom programming. Each time JumpStart is executed, all options will be reset to their default values. Do not run JumpStart after you have configured the system through programming.

Agency Listings/Requirements

NFPA
Install for commercial use in accordance with NFPA 13, NFPA 15, NFPA 16 and NFPA 72.

The IFP-2000ECS is suitable as:
Local signaling unit
Commercial protected premises control unit
Remote signaling protected premises unit
Auxiliary protective signaling unit.
Also suitable for use as a control unit for releasing device service.

The IFP-2000ECS is suitable for the following types of signaling services:
automatic, manual, waterflow, sprinkler supervisory, DACT,
Reverse polarity,
Coded,
Non-Coded
System must be fully tested after installation.

MEA Approval Number

CSFM Approval Number

F.C.C. Information

This device has been verified to comply with FCC Rules Part 15, Class A. Operation is subject to the following conditions:

- 1) This device may not cause radio interference;
- 2) This device must accept any interference received, including any that may cause undesired operation.

FCC registration number: US:AC6AL11B6820
Ringer equivalence: .8B

Intended for indoor use in dry locations only.


Silent Knight IFP-2000ECS/HV Wiring Diagram P/N LS10052-001SK-E Rev A ECN 12-0880

This product is to be installed in accordance with Installation Manual P/N 151430 Rev ____

For control panel operation, see P/N 151432 Rev ____ and LS10049-001SK-E Rev ____

Flexput™ and JumpStart® are Trademarks of Silent Knight
Gentex®, AMSECO®, System Sensor® and Wheelock® synchronization protocols are used by permission


Wheelock® Pat. Nos. 5,400,009, 5,608,375 and 5,982,275





ON
OFF

Address								
1	2	3	4	5	6	0	11	22
0	0	0	0	0	0	11	11	11
1	0	0	0	0	0	12	12	12
2	0	0	0	0	0	13	13	13
3	0	0	0	0	0	14	14	14
4	0	0	0	0	0	15	15	15
5	0	0	0	0	0	16	16	16
6	0	0	0	0	0	17	17	17
7	0	0	0	0	0	18	18	18
8	0	0	0	0	0	19	19	19
9	0	0	0	0	0	20	20	20
10	0	0	0	0	0	21	21	21

SBUS Addressing



SBUS Wiring from ECS-VCM to FACP



Connection from ECS-VCM to ECS-SW24