



GTPR.R14531 Fire Door Holders

[Page Bottom](#)

Fire Door Holders

[See General Information for Fire Door Holders](#)

FIRE-LITE ALARMS

R14531

1 FIRE-LITE PL
NORTHFORD, CT 06472 USA

Electro-magnetic door holders, rated 0.068 amp, 24 v, dc, 0.017 amp, 120 v.

Models DH150A, -154A, -158A rated 24 v, ac/dc.

Models DH150N, -154N, -158N rated 120 v, ac.

Models FM980, -996, -998 may be followed by 24 or 120 rated 0.068 amp, 24 v, dc, 0.180 amp, 12 v, dc, 0.017 amp, 120 v, ac, 0.080 amp, 24 v, ac, 0.140 amp 12 v, ac, 0.009 amp, 250 v, ac, 277 v, ac.

[Last Updated](#) on 2007-07-13

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2008 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.

