



UROX.S24850 Smoke-automatic Fire Detectors

[Page Bottom](#)

Smoke-automatic Fire Detectors

[See General Information for Smoke-automatic Fire Detectors](#)**HONEYWELL INTERNATIONAL INC**

S24850

12 CLINTONVILLE RD
NORTHFORD, CT 06472 USA

Detector			Compatibility		Velocity Range (fpm)	
Model	Application	Type	Restrictions		Min	Max
HFS-DPR	OAP, D(I)	P	D2		0	4000
HFS-P	OAP	P	D2		0	4000
HFS-PT	OAP	P(IHD)	D2		0	4000

Detector			Compatibility		Velocity Range (fpm)		Pressure Differential Between Sampling Tube	
Model	Application	Type	Restrictions	Min	Max	Min	Max	
HFS-D (a) (b)	D(ST)	P	D2	100	4000	0.01	1.11	

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

OAP - Open Area Protection

D(I) - Duct Detector - Installation Inside Duct

P - Photoelectric

IHD - Includes Integral Heat Detector

D(ST) - Duct Detector - Sampling Tubes

(a) - Suitable for elevated temperatures up to 70 C.

(b) - HFS-D duct housing can be used with the following compatible detector heads: HFS-DPR

Last Updated on 2011-08-05

[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

© 2013 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2013 UL LLC".