



## UNIUC.S711 Boxes, Non-Coded, Fire Alarm

[Page Bottom](#)

### Boxes, Non-Coded, Fire Alarm

[See General Information for Boxes, Non-Coded, Fire Alarm](#)

#### **FIRE-LITE ALARMS**

S711

1 FIRE-LITE PL  
NORTHFORD, CT 06472 USA

Model BG-8, Input: 24-30 V dc, 1.0 A; Model BG-10, Input: 24-30 V dc, 3.0 A.

[Last Updated](#) on 2007-07-13

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters' Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters' Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge.

