



**UOJZ7.S624  
Control Units, System Certified for Canada**

[Page Bottom](#)

**Control Units, System Certified for Canada**

[See General Information for Control Units, System Certified for Canada](#)

**FIRE-LITE ALARMS**

S624

1 Fire-lite PI

Northford, CT 06472 USA

Model	Control Unit System Type(s)	Initiating Device Type(s)	Signaling Type(s)
<b>Subassembly</b>			
<b>PWRMOD24</b>	AUX, CS (PPU), L, P (PPU), RS (PPU)	A, CO, M, SS, WF, WSS	C, DAC, March, NC, T4, PB, Rev Pol
<b>ES-200XC</b>	AUX	A, M, WF	Rev Pol
	L	A, M, SS, WF	March, NC, T4
	RS (PPU)	A, M, SS, WF	DAC, PB, Rev Pol
	P (PPU)	A, M, SS, WF	DAC, PB, Rev Pol
	CS (PPU)	A, M, SS, WF	DAC, PB, Rev Pol
<b>ES-50XC</b>	AUX	A, M, WF	Rev Pol
	L	A, M, SS, WF	March, NC, T4
	RS (PPU)	A, M, SS, WF	DAC, PB, Rev Pol
	P (PPU)	A, M, SS, WF	DAC, PB, Rev Pol
	CS (PPU)	A, M, SS, WF	DAC, PB, Rev Pol

**For Replacement Only - Complies with ULC-S527**

<b>Replacement Parts Only (Complies with S527-99)</b>			
Model	Control Unit System Type(s)	Initiating Device Type(s)	Signaling Type(s)
<b>MS-5UD-7C (+), MS-5UD-7C-FR (+), MS-10UD-7C (+), MS-10UD-7C-FR (+)</b>	L	A, M, SS, WF	March, NC
	RS	A, M, SS, WF	DAC, Rev Pol
	CS (PPU)	A, M, SS, WF	DAC
	AUX	A, M, WF	NC
<b>MS-9050UDC (+), MS-9050UDC-FR (+)</b>	AUX	A, M, WF	NC
	CS (PPU)	A, M, SS, WF	DAC
	L	A, M, SS, WF	March, NC
	RS (PPU)	A, M, SS, WF	DAC, Rev

			Pol
<b>MS-9600LSC (+), MS-9600LSC-FR(+)</b>	L	A, M, SS, WF	NC
	RS (PPU)	A, M, SS, WF	DAC
	AUX	A, M, WF	NC
	CS (PPU)	A, M, SS, WF	DAC

**Fire Alarm Subassemblies, Backbox**, Model(s) 05258, 05280

**Fire Alarm Subassemblies, Door**, Model(s) 05258C, 05280C

**Fire Alarm Subassemblies, Dress Panel**, Model(s) 18783, 18784

**Fire Alarm Subassemblies, Transmitter module**, Model(s) 4XTMF

**Fire Alarm Subassembly**, Model(s) BB-6F

**Local System Type**, Model(s) MRP-2001C, MRP-2001C-FR, MRP-2002C, MRP-2002C-FR

**Subassembly**, Model(s) CAC-5X Class A Conversion Module, IPOTS-COM

**For Replacement Only - Complies with ULC-S527**

**Fire Alarm Subassemblies, Motherboard**, Model(s) 50131614-001, 50131615-001, 50131616-001, 50131617-001, 50131618-001, 50131619-001, 50131620-001, 50131621-001

**Subassembly**, Model(s) ZNAC-92 Class A Conversion Module

**Transformer**, Model(s) XRM-24B Transformer

AUX - Auxiliary System

CS (PPU) - Central Station System (Protected Premises Unit)

L - Local System

P (PPU) - Proprietary System (Protected Premises Unit)

RS (PPU) - Remote Station System (Protected Premises Unit)

A - Automatic Fire Alarm: thermostats, smoke detectors, etc.

CO - Carbon Monoxide Alarm: carbon monoxide detectors

M - Manual Fire Alarm: manually operated boxes

SS - Supervisory: gate valves, water-level switches, temperature switches, carbon monoxide alarm, residential fire alarm control units, etc.

WF - Waterflow Alarm: waterflow switches

WSS - Watchman's Supervisory Service

C - Coded

DAC - Digital Alarm Communicator

March - March Time

NC - Noncoded, Steady, Temporal 3 Pattern, etc.

T4 - Temporal 4 Pattern

PB - Performance Based Technologies

Rev Pol - Reverse Polarity

RS - Remote Station System

+ - Must be employed with additional specific Listed device(s) as indicated in control unit installation instructions and wiring diagrams to provide indicated System Type and/or Type Signaling.

[Last Updated](#) on 2017-12-26

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2018 Underwriters Laboratories of Canada Inc."