

UOJZC.S624 Control Units, System, Fire Alarm

[Page Bottom](#)

Control Units, System, Fire Alarm

[See General Information for Control Units, System, Fire Alarm](#)

FIRE-LITE ALARMS

S624

1 FIRE-LITE PL
NORTHFORD, CT 06472 USA

Local, Auxiliary and Remote Station (Protected Premises), Model Sensiscan 200, Input: 120 V, 60 Hz, 1.8 A; Models Sensiscan 2000, MS-9200 and AMS-9200, Input: 120 V, 60 Hz, 2.3 A. Models MS-9200 and AMS-9200 must be provided with a separate annunciator made by Fire-Lite Alarms. Model MS-2410BC, Input: 120 V, 60 Hz, 2.3 A.

Addressable Control Unit, Model MS-9600, Input: 120 V, 60 Hz, 3.2 A.

Local System Type, Models MS-4424, MS-4424B and MRP-4424, Input: 120 V, 60 Hz, 1.2 A. Models CMP-2401B and CMP-2402B, Input: 120 V, 60 Hz, 0.5 A.

[Last Updated](#) on 2007-07-13

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

[Copyright © 2008 Underwriters' Laboratories of Canada®](#)

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters' Laboratories of Canada" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2008 Underwriters' Laboratories of Canada®"

An independent organization working for a safer world with integrity, precision and knowledge.

