



**UQGS7.S2517**  
**Heat-automatic Fire Detectors Certified for Canada**

[Page Bottom](#)

**Heat-automatic Fire Detectors Certified for Canada**

[See General Information for Heat-automatic Fire Detectors Certified for Canada](#)**FIRE-LITE ALARMS**

S2517

1 Fire-lite PI

Northford, CT 06472 USA

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
H355A	FT	None	-	-	-	-
H355HTA	FT	None	-	-	-	-
H355RA	FT	None	-	-	-	-
H365A	FT	D1	-	135	50	25
H365A-IV	FT	D1	-	135	50	25
H365HTA	FT	D1	-	190	50	25
H365HTA-IV	FT	D1	-	190	50	25
H365RA	FT/ROR	D1	-	135	50	25
H365RA-IV	FT/ROR	D1	-	135	50	25

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

Note - Electrical ratings: Model FR: 6-120 v, ac, 1 amp; 6-24 v, dc, 0.5 amp. Models 302, 302H, 6-125 v, ac, 5 amp; 6-25 v, dc, 1.0 amp; 125 v, dc, 0.5 amp. Models 501, 502, 503, 504, 601, 602, 603, 604, 621, 622, 623, 624, 3 amp, 6-125 v, ac; 1 amp, 6-28 v, dc; 0.3 amp, 125 v, dc; 0.1 amp, 250 v, dc. Models A, AT, 6-125 v, ac, 6 amp; 6-28 v, dc, 3 amp; 125 v, dc, 1 amp; 250 v, dc, 0.3 amp.

[Last Updated](#) on 2017-12-07[Questions?](#)[Print this page](#)[Terms of Use](#)[Page Top](#)

Copyright © 2018 Underwriters Laboratories of Canada Inc.

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under ULC's Follow-Up Service. Only those products bearing the ULC Mark should be considered to be Listed and covered under ULC's Follow-Up Service. Always look for the Mark on the product.

ULC permits the reproduction of the material contained in the ULC Online Directories subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the ULC Online Directories with permission from Underwriters Laboratories of Canada Inc." must appear adjacent to the extracted material. In addition, the reprinted material must

include a copyright notice in the following format: "Copyright © 2018 Underwriters Laboratories of Canada Inc."