


This Product Installation Document outlines the connection of a UL-864 Listed Central Station/Remote Station Transmitter to Fire-Lite Fire Alarm Control Panel dry contacts. The FACP contacts must be supervised by the Central Station/Remote Station Transmitter module using End-of-Line Resistors (ELRs) with a value determined by the Transmitter manufacturer. Power is also provided by the Central Station/Remote Station Transmitter manufacturer. Refer to the Central Station/Remote Station Transmitter manufacturer's manual for details.



\*Note: The Trouble Relay is a fail-safe relay. With power applied to the FACP and no troubles in the panel, the contacts should be in the condition indicated in the illustration.

For detailed information on specific Fire-Lite FACPs refer to the appropriate panel manual as listed below:

- MS-9200UD Manual P/N: 51906
- MS-9200UDLS Manual P/N: 52750
- MS-9600 Manual P/N: 51335
- MS-9050UD Manual P/N: 52413
- MS-4 Manual P/N: 51512
- MS-5210UD Manual P/N: 50193 (requires use of optional NAC-REM module for supervisory relay)