



UQGS.S6228
Heat-automatic Fire Detectors

[Page Bottom](#)

Heat-automatic Fire Detectors

[See General Information for Heat-automatic Fire Detectors](#)**SILENT KNIGHT BY HONEYWELL**

S6228

1985 Douglas Dr

MN10-212A

Golden Valley, MN 55422 USA

Model No.	Type	Compatibility Restrictions	Contact Arrangement	Temp Range (°F)	Spacing (Ft)	
					Smooth Ceiling	to Wall or Partition
IDP-Heat	FT	D1	-	135	50	25
IDP-Heat-HT	FT	D1	-	190	50	25
IDP-HEAT-HT-IV	FT	D1	-	190	50	25
IDP-HEAT-HT-W	FT	D1	-	190	50	25
IDP-HEAT-IV	FT	D1	-	135	50	25
IDP-Heat-ROR	FT/ROR	None	-	135	50	25
IDP-HEAT-ROR-IV	FT/ROR	D1	-	135	50	25
IDP-HEAT-ROR-W	FT/ROR	D1	-	135	50	25
IDP-HEAT-W	FT	D1	-	135	50	25
SD505-AHS	FT	None	-	135-150	70	25
SD505-HEAT	FT/ROR	D2	-	135-194	70	35
SK-HEAT	FT	D1	-	135	50	25
SK-HEAT-HT	FT	D1	-	190	50	25
SK-HEAT-HT-W	FT	D1	-	190	50	25
SK-HEAT-ROR	FT/ROR	None	-	135	50	25
SK-HEAT-ROR-W	FT/ROR	D1	-	135	50	25
SK-HEAT-W	FT	D1	-	135	50	25
WIDP-HEAT	FT	D1	-	135	50	25
WIDP-HEAT-ROR	FT/ROR	D1	-	135	50	25
WSK-HEAT	FT	D1	-	135	50	25
WSK-HEAT-ROR	FT/ROR	D1	-	135	50	25

Base Model	Related Detector	Control Unit Compatibility Restrictions
SD505-6AB	SD505-APS	None

D1 - Listing limited to specific system control unit. Information on compatible control unit indicated on installation drawing of control unit and/or detector.

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.

FT - Fixed temperature

FT/ROR - Fixed temperature/rate of rise combination

D2 - For connection to Listed control units with which compatibility was determined by test or a review of circuit parameters. Interconnection and compatible models indicated on installation wiring diagram for detector (base) and/or control unit.



Trademark and/or Tradename:

[Last Updated](#) on 2017-12-19

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2018 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2018 UL LLC".