



Reg. No. 010/P-012

# EVPÚ<sup>®</sup>



## CERTIFICATE No. 00072/101/1/2023

on October 17<sup>th</sup>, 2023

Certification body of EVPÚ a.s. confirms the compliance of the products with requirements of undermentioned standard.

Product: **Fire detection and fire alarm system**

Type: **Fire detection and fire alarm system with control and indicated equipment MA-2000**

The list of system compatible components: **See Annex No. 1**

Specification: **100-120VAC, 3A, 200-240VAC, 1.7A 50/60Hz**

Client: **Notifier Italia S.r.l.,  
Via Grandi, 22, 20097 San Donato Milanese (MI), Italy**

Manufacturer: **Notifier Italia S.r.l.,  
Via Grandi, 22, 20097 San Donato Milanese (MI), Italy**

Standard: **EN 54-13: 2017 + A1: 2019**

Results of tests of mentioned products are summarized in Final report on assessment No. **0-0237/23/C** of **October 17<sup>th</sup>, 2023**.

Validity of certificate  
is limited for the period  
from: **October 17<sup>th</sup>, 2023**  
until: **October 16<sup>th</sup>, 2026**



Michal Mišiak

Any significant changes in the design or construction of the products or amendments of the technical decrees reference above may render this Certificate invalid. The product liability rests with the manufacturer or his representative.

EVPÚ a.s., Trenčianska 19, 018 51 Nová Dubnica, Slovak republic, [www.evpu.sk](http://www.evpu.sk)

054741

## The list of system compatible components (part 1):

| FDAS component | Component description                                      | CPR            |
|----------------|--|----------------|
| MA-2000        | addressable fire detection panel                           | 0370-CPR-6094  |
| MA-LCD7        | Active Repeater Panel for Max Range of panel               | -              |
| Detectors      |  |                |
| MI-PSE-S2      | Low profile Optical Smoke Sensor - White.                  | 0786-CPR-20745 |
| MI-PSE-S2I     | Low profile Optical Smoke Sensor - WHITE - c/w SCI         | 0786-CPR-20739 |
| MI-PSE-S2-IV   | OPT DET NO ISO IV MORLEY IAS                               | 0786-CPR-20745 |
| MI-PTIR-S2     | Smoke / Heat / IR Sensor - WHITE                           | 0786-CPR-20743 |
| MI-PTIR-S2I    | Smoke / Heat / IR Sensor - WHITE - c/w SCI                 | 0786-CPR-20737 |
| MI-PTIR-S2-IV  | PTIR DET NO ISO IVORY MORLEY                               | 0786-CPR-20743 |
| MI-PTSE-S2     | PH/TH DET NO ISO MORLEY                                    | 0786-CPR-20744 |
| MI-PTSE-S2I    | PH/TH DET ISO MORLEY                                       | 0786-CPR-20738 |
| MI-PTSE-S2-IV  | PH/TH DET NO ISO IVORY MORLEY                              | 0786-CPR-20744 |
| MI-FHSE-S2     | Heat sensor. 58 °C, EN54 part 5. Type A1 - WHITE           | 0786-CPD-20746 |
| MI-FHSE-S2I    | Heat sensor. 58 °C, EN54 part 5. Type A1 - WHITE - c/w SCI | 0786-CPD-20740 |
| MI-FHSE-S2-IV  | 58°C FIX TH NO ISO IV MORLEY                               | 0786-CPD-20746 |
| MI-HTSE-S2     | High temp heat sensor, 78 °C - WHITE                       | 0786-CPD-20747 |
| MI-HTSE-S2I    | High temp heat sensor, 78 °C - WHITE - c/w SCI             | 0786-CPD-20741 |
| MI-HTSE-S2-IV  | 78°C FIX TH NO ISO IV MORLEY                               | 0786-CPD-20747 |
| HM-PSE-AP      | ADDRESSABLE SMOKE DETECTOR AP PROTOCOL                     | 550q/02        |
| HM-PSE-I-AP    | ADDRESS SMOKE DET WITH INBUILT ISOLATOR AP PROTOCOL        | 550q/02        |
| HM-RHSE-AP     | ADDRESSABLE ROR HEAT DETECTOR AP PROTOCOL                  | 550m(cl-1)     |
| HM-RHSE-I-AP   | ADD ROR HEAT DET WITH INBUILT ISOLATOR AP PROTOCOL         | 2831-CPR-F1767 |
| HM-FHSE-AP     | ADDRESS FIXED HEAT DETECTOR AP PROTOCOL                    | 550m(cl-1)     |
| HM-FHSE-I-AP   | ADD FIXD HEAT DET WIT INBUILT ISOLATOR AP PROTOCOL         | 2831-CPR-F1769 |
| HM/FHSE        | Fixed heat detector  | 2831-CPR-F1768 |
| HM/FHSE/I      | Fixed heat detector with Isolator                          | 2831-CPR-F1769 |
| HM/PSE         | Smoke detector   | 2831-CPR-F1764 |
| HM/PSE/I       | Smoke detector with Isolator                               | 2831-CPR-F1765 |
| HM/PSE/S2      | Smoke detector without Isolator                            | 2831-CPR-F2057 |
| HM/PSE/S2/I    | Smoke detector with Isolator                               | 2831-CPR-F2058 |



## The list of system compatible components (part 2):


|                           |  |                   |
|---------------------------|--|-------------------|
| HM/PTSE                   | Photo Thermal detector                                   | 2831-CPR-F1770    |
| HM/PTSE/I                 | Photo Thermal detector with Isolator                     | 2831-CPR-F1771    |
| HM/RHSE                   | ROR heat detector  | 2831-CPR-F1766    |
| HM/RHSE/I                 | ROR heat detector with Isolator                          | 2831-CPR-F1767    |
| MI/B501AP/IV              | MIAS 200 Series Advance Base                             | -                 |
| B501AP                    | Detector Base Pure With                                  | -                 |
| B501AP-IV                 | Detector Base Ivory                                      | -                 |
| MI-RHSE-S2                | Heat sensor. 58 °C & RoR (Type A1R) - WHITE              | 0786-CPD-20748    |
| MI-RHSE-S2I               | Heat sensor. 58 °C & RoR (Type A1R) - WHITE - c/w SCI    | 0786-CPD-20742    |
| MI-RHSE-S2-IV             | ROR TH NO ISO IVORY MORLEY IAS                           | 0786-CPD-20748    |
| MI-LPB2-S3I               | Optical beam detector based on reflective technology.    | 1293-CPR-0692     |
| MI-LPB2-S3I-40            | Intelligent Beam Detector (Short) Morley                 | 1293-CPR-0692     |
| MI-LZR-S3I                | Intelligent Beam Detector Morley                         | 2831-CPR-F2558    |
| MI-OSI-RIE                | INT BEAM MORLEY EUR - ADV PROTOCOL                       | 0333-CPR-075624-2 |
| <b>Manual Call Points</b> |  |                   |
| MI-MCP-FLEX               | Manual call point, Flexible element included             | 2831-CPR-F1748    |
| MI-MCP-FLEX/C             | Intelligent Indoor Manual Call Point Flexi, not isolated | 2831-CPR-F1748    |
| MI-MCP-FLEX-I             | Manual call point, Flexible element included - c/w SCI   | 2831-CPR-F1756    |
| MI-MCP-FLEX-I/C           | Intelligent Indoor Manual Call Point Flexi, isolated     | 2831-CPR-F1756    |
| MI-MCP-GLASS              | Manual call point. Glass element included                | 2831-CPR-F1748    |
| MI-MCP-GLASS-I            | Manual call point, Glass element included - c/w SCI      | 2831-CPR-F1756    |
| MI-WCP-R/I/SG             | Waterproof manual call point, IP67 - c/w SCI             | 2831-CPR-F1758    |
| MI-WCP-R/I/SG/C           | Intelligent Outdoor Manual Call Point glass, isolated    | 2831-CPR-F1758    |
| MI-WCP-R/SG               | Waterproof manual call point, IP 67.                     | 2831-CPR-F1753    |
| MI-WCP-R/SF               | Waterproof manual call point, IP 67. Flexi               | 2831-CPR-F1753    |
| MI-WCP-R/I/SF/C           | Intelligent Outdoor Manual Call Point flexi, isolated    | 2831-CPR-F1758    |
| HM/MCP/GLASS              | MCP, MORLEY, LPCB  | C550h-(cl-2)      |
| MCPSC-MI                  | MCP ADDRESSABLE CLIP PROT. MORLAY                        | 2852-CPR-0123     |
| WCPSC-MI                  | WCP ADDRESSABLE CLIP PROT. MORLAY                        | 2852-CPR-0123     |

054687




## The list of system compatible components (part 3):

| Modules        |   |                  |
|----------------|---|------------------|
| MI/D240CMO     | OUTPUT MODULE 240V, MIAS, IN  | 2821-CPR-F1604   |
| MI/D2ICMO      | 2 INPUT, 1 OUTPUT MODULE, MIAS, IN                                  | 2831-CPR-F1608   |
| MI/DCMO        | OUTPUT MODULE, MIAS, IN   | 2831-CPR-F1603   |
| MI/DCZRM       | CONVENTIONAL ZONE MODULE, MIAS, IN                                  | 2831-CPR-F1609   |
| MI/DISO        | ISOLATOR MODULE, MIAS, IN   | 2831-CPR-F1602   |
| MI/DMM2I       | INPUT MODULE DUAL, MIAS, IN   | 2831-CPR-F1607   |
| MI/DMMI        | INPUT MODULE SINGLE, MIAS, IN                                       | 2831-CPR-F1606   |
| MI-CR6-S2I     | six way changeover relay output with built-in loop isolation        | 0905-CPR-191780  |
| MMA1-MI        | 1 Input Module Mini   | 1293-CPR-0801    |
| CMA1-MI        | 1 Output Module Mini  | 1293-CPR-0803    |
| MI-CZ6         | 6-WAY INTERFACE MULTI-MODULE  | 2831-CPR-F1534   |
| MI-D240CMO     | AA 240VAC OUTPUT MODULE MP  | 0786-CPR-21658   |
| MI-D240CMO-DIN | AA 240VAC OUTPUT MODULE MP DIN                                      | 0786-CPR-21658   |
| MI-D240CMOE    | Output Control Module, 240 Vac relay contact c/w surface enclosure. | 0786_CPR-21748   |
| MI-D2ICMO      | 2 INPUT, 1 OUT MODULE - MORLEY                                      | 0786-CPR-21648   |
| CMX-10RME-MI   | 10 Output   | 1293-CPR-0839    |
| MMX-10ME-MI    | 10 Input  | 1293-CPR-0840    |
| MCX-55ME-MI    | 5 Input / 5 Output  | 1293-CPR-0841    |
| MI/D2ICMOE     | 2 INPUT, 1 OUTPUT MODULE, MIAS, IN                                  | 0905-CPR-221123  |
| MI/DCMOE       | OUTPUT MODULE, MIAS, IN   | 0905-CPR-221123  |
| MI/DMM2IE      | INPUT MODULE DUAL, MIAS, IN   | 2831-CPR-F1607   |
| MI/DMMIE       | INPUT MODULE SINGLE, MIAS, IN                                       | 2831-CPR-F1606   |
| MI-D2ICMOE     | Dual input and single control output combination module             | 0905-CPR-210492  |
| MI-DCMO        | ANALOGUE I/FACE DET IAS O/P I/FACE MODULE                           | 0786-CPR-21658   |
| MI-DCMOE       | Output control module   | 0905-CPR-210492  |
| MI-DCZM        | CONVENT.ZONE MONITOR MODULE   | 2831-CPR-F4276   |
| MI-DCZRM       | CONVENTIONAL ZONE MODULE  | 2831-CPR-F4277   |
| MI-DCZRME      | Addressable zone monitor module                                     | 0905-CPR-220802  |
| MI-DISO        | Loop isolation module   | 0786-CPR-21643   |
| MI-DMM2I       | DUAL INPUT MODULE - MORLEY IAS                                      | 0786-CPR-21653   |
| MI-DMM2IE      | Dual Input monitor module   | 0905-CPR-210492  |
| MI-DMMI        | SINGLE INPUT MODULE-MORLEY IAS                                      | 0786-CPR-21653   |
| MI-DMMIE       | Single Input monitor module   | 0905-CPR-210492  |
| MI-IM10-S2I    | Ten input monitor module  | 0905-CPR-191779  |
| MI-MM3E-S2     | Addressable "mini" input module                                     | 0905-CPR-00176_3 |




## The list of system compatible components (part 4):

| Sounder - Flash |   |                |
|-----------------|---|----------------|
| MI-BGL-PC-I     | Intelligent Detector Base Strobe Only<br>EN54-23 C Class, pure white clear lens     | 2831-CPR-F4469 |
| MI-BRH-PC-I     | Intelligent Detector Base High<br>Performance Sounder Strobe EN54-23<br>C Class     | 2831-CPR-F4463 |
| MIBRS-PC-I      | Intelligent Detector Base Standard<br>Performance Sounder Strobe EN54-23<br>C Class | 2831-CPR-F4466 |
| MI-BSO-DD-I     | Intelligent Detector Base Sounder Ivory<br>Colour Isolated                          | 2831-CPR-F2255 |
| MI-BSO-DD-N     | Intelligent Detector Base Sounder Ivory<br>Colour Not Isolated                      | 2831-CPR-F2251 |
| MI-BSO-PP-I     | Sensor Sounder Base – WHITE skirt –<br>c/w SCI                                      | 2831-CPR-F2255 |
| MI-BSO-PP-N     | Sensor Sounder Base – WHITE skirt   | 2831-CPR-F2251 |
| MI-DSS-PC-I     | Sensor Sounder Strobe Base – White<br>skirt/Clear lens + SCI                        | 2831-CPR-F2089 |
| MI-DSS-PC-N     | Sensor Sounder Strobe Base – White<br>skirt/Clear lens                              | 2831-CPR-F2085 |
| MI-WSO-PP-I     | WHITE Body Sounder –c/w SCI   | 2831-CPR-F2253 |
| MI-WSO-PP-N     | WHITE Body Sounder  | 2831-CPR-F2249 |
| MI-WSO-PR-I     | RED body Sounder – c/w SCI  | 2831-CPR-F2253 |
| MI-WSO-PR-N     | RED body Sounder  | 2831-CPR-F2249 |
| MI-WSS-PC-I     | Intelligent Wall Mount Sounder Strobe<br>EN54-23 O Class                            | 2831-CPR-F0726 |
| MI-WSS-PC-N     | WHITE body sounder RED VAD c/w<br>CLEAR lens (EN54-23 O Class<br>approved)          | 2831-CPR-F0274 |
| MI-WSS-PR-I     | WHITE body Sounder RED VID c/w<br>RED lens (non EN54-23) & SCI                      | 2831-CPR-F2254 |
| MI-WSS-PR-N     | WHITE body Sounder RED VID c/w lens<br>(non EN54-23)                                | 2831-CPR-F0269 |
| MI-WST-PC-I     | Intelligent Wall Mounted Strobe Pure<br>White Red Lens Isolated                     | 2831-CPR-F2250 |
| MI-WST-PR-N     | WHITE body RED VAD c/w CLEAR lens<br>(EN54-23 O Class approved) Isolated            | 2831-CPR-F2250 |
| MI-WST-PC-N     | Intelligent WALL Mounted Strobe Pure<br>White Red Lens, Not Isolated                | 2831-CPR-F0272 |
| WPW             | AV PHASE II WHITE W/PROOF DEEP<br>BASE  | -              |
| WRR             | AV PHASE II RED W/PROOF DEEP<br>BASE  | -              |




**The list of system compatible components (part 5):**

| <b>Aspiration systems</b>                         |  |                  |
|---|--|------------------|
| MI-FL2011EI-HS                                    | FAAST LT Single Channel Morley Loop                                    | 2831-CPR-F1056   |
| MI-FL2012EI-HS                                    | FAAST LT DOUBLE KNOCK MORLEY LOOP                                      | 2831-CPR-F1057   |
| MI-FL2022EI-HS                                    | FAAST LT Dual Channel Morley Loop                                      | 2831-CPR-F1058   |
| <b>Wireless Devices</b>                           |  |                  |
| MI-GATE   | S200RF Gateway Module Morley-IAS                                       | 0333-CPR-075608  |
| 22051E-RF   | Photo Detector   | 0333-CPR-075561  |
| 22051TLE-RF                                       | Multi-Criteria: Photo-Thermal-IR Detector                              | 0333-CPR-075487  |
| 52051E-RF   | 58°C Fixed Temperature Heat Detector                                   | G 217070         |
| 52051RE-RF  | Rate of Rise Heat Detector   | G 217069         |
| M200F-RF  | Repeater, providing larger area coverage and more robust communication | 0333-CPR-075501  |
| M200G-RF  | Gateway radio network Fire Detection system                            | G 217065         |
| R5A-RF  | Waterproof Manual Call Point   | 0333-CPR-075496  |
| M200I-RF  | Remote Indicator   | -                |
| M211E-RF  | I/O Module   | 0333-CPR-075600  |
| WSO-RR-RF   | SS Wall Mounted Addressable Sounder Red                                | 0905-CPR-00819_2 |
| WSO-WW-RF   | SS Wall Mounted Addressable Sounder White                              | 0905-CPR-00819_2 |
| WSS-RR-RF   | Wall Mounted Sounder VAD, red led, red lens                            | 0905-CPR-201262  |
| WSS-WR-RF   | Wall Mounted Sounder VAD, red led, clear lens                          | 0905-CPR-201262  |
| WSF-RR-RF   | Wall Mounted Sounder VAD, red led red lens                             | 0905-CPR-201262  |
| WSF-WR-RF   | Wall Mounted Sounder VAD, red led, clear lens                          | 0905-CPR-201262  |
| MI-RF-USB-PRO                                     | USB Dongle RF 868 MHz Morley les PRO                                   | -                |
| M200WC-RF   | USB Wireless Dongle, for Wireless Fire System interfacing              | -                |
| <b>Conventional Devices</b>                       |  |                  |
| <b>Thermal detector connected by Input Module</b> |  |                  |
| TMP2-D-xxx  | Heat detector  | 0068-CPR-009     |
| TMP2-JO-xxx                                       | Heat detector  | 0068-CPR-009     |




## The list of system compatible components (part 6):

| <b>Beam detector connected by Input Module</b>  |                            |                            |
|---|----------------------------|----------------------------|
| 6500RE  | Conventional beam detector | 1293-CPR-0684              |
| 6500RSE   | Conventional beam detector | 1293-CPR-0684              |
| ES-50   | Conventional beam detector | 0786-CPR-20214             |
| ES-25I  | Conventional beam detector | 0786-CPR-20214             |
| B100  | Conventional beam detector | 0786-CPR-20264             |
| AS/2-100  | Conventional beam detector | 0786-CPR-20215             |
| ASF100 DS-1                                     | Conventional beam detector | 0786-CPR-20215             |
| ASF-100   | Conventional beam detector | 0786-CPR-20215             |
| BS70  | Conventional beam detector | 0786-CPR-20216             |
| BSF70   | Conventional beam detector | 0786-CPR-20216             |
| BS150   | Conventional beam detector | 0786-CPR-20216             |
| BSF150  | Conventional beam detector | 0786-CPR-20216             |
| BOOMER.ILIA                                     | Conventional beam detector | 0786-CPR-20925             |
| TX-RX ILIA                                      | Conventional beam detector | 0786-CPR-20925             |
| CSRLS-2   | Conventional beam detector | 0786-CPR-20925             |
| CSRLS-2-DUST-L7                                 | Conventional beam detector | 0786-CPR-20925             |
| EXP-ILIA2/8                                     | Conventional beam detector | 0786-CPR-20925             |
| ERHS0712-PRO                                    | Conventional beam detector | 0786-CPR-20925             |
| CSRLS-PRO                                       | Conventional beam detector | 0786-CPR-20925             |
| ILEXD   | Conventional beam detector | DC-13-416_r0B_DC-15-427-r0 |
| OSI-10  | OSID receiver unit         | 0333-CPR-075387            |
| OSI-90  | OSID receiver unit         | 0333-CPR-075387            |
| OSE-SP-01                                       | OSID receiver unit         | 0333-CPR-075387            |
| OSE-SPW   | OSID receiver unit         | 0333-CPR-075387            |
| OSE-HP-01                                       | OSID receiver unit         | 0333-CPR-075387            |
| OSE-HPW   | OSID receiver unit         | 0333-CPR-075387            |
| OSI-RE-SS                                       | Conventional Beam detector | 033-CPR-075624             |
| <b>Flame detector connected by Input Module</b> |                            |                            |
| 20/20-MI-R                                      | Flame Detector             | 0786-CPR-21343             |
| 40/40DLB631SCY7                                 | Flame Detector             | 2809-CPR-E0014             |
| 40/40DL4B631SCY7                                | Flame Detector             | 2809-CPR-E0014             |
| 40/40DI631SCY7                                  | Flame Detector             | 2809-CPR-E0014             |
| 40/40DM631SCY7                                  | Flame Detector             | 2809-CPR-E0014             |
| FS20X-211-23-6                                  | Flame Detector             | 0832-CPR-F0515             |
| FS20X-211-24-6                                  | Flame Detector             | 0832-CPR-F0515             |
| FS24X-911-23-6                                  | Flame Detector             | 0832-CPR-F0515             |
| FS24X-911-24-6                                  | Flame Detector             | 0832-CPR-F0515             |



## The list of system compatible components (part 7):


|   |                               |                   |
|---|-------------------------------|-------------------|
| FSL100-UV   | Flame Detector                | -                 |
| FSL100-UVIR   | Flame Detector                | -                 |
| FSL100-IR3  | Flame Detector                | -                 |
| RIV-601/F   | Flame Detector                | 0786-CPR-21103    |
| RIV-601/FA  | Flame Detector                | 0786-CPR-21103    |
| RIV-601/S   | Flame Detector                | 0786-CPR-21103    |
| <b>Conventional MCP connected by Input Module</b>               |                               |                   |
| M3A-R000SG-STCK-01  | Manual call point             | 2831-CPR-F1709    |
| M3A-R000SF-STCK-01  | Manual call point             | 2831-CPR-F1709    |
| W3A-R000SG-STCK-01  | Manual call point             | 2831-CPR-F1723    |
| W3A-R000SF-K013-01  | Manual call point             | 2831-CPR-F1723    |
| W3A-Y000SG-K013-14  | Manual call point             | 1035-CPR-ES067290 |
| M3A-B000SG-K013-11  | Manual call point             | 1035-CPR-ES067290 |
| <b>Conventional sounders / flash connected by Output Module</b> |                               |                   |
| CWSO-RR-S1  | Conventional sounder          | 2831-CPR-F0254    |
| CWSO-RR-W1  | Conventional sounder          | 2831-CPR-F0254    |
| CWST-RW-S5  | Conventional Beacon           | 2831-CPR-F0257    |
| CWST-RR-S5  | Conventional Beacon           | 2831-CPR-F0258    |
| CWST-RW-W5  | Conventional Beacon           | 2831-CPR-F0257    |
| CWST-RR-W5  | Conventional Beacon           | 2831-CPR-F0258    |
| CWSS-RR-S3  | Conventional Sounder / Beacon | 2831-CPR-F0262    |
| CWSS-RW-S5  | Conventional Sounder / Beacon | 2831-CPR-F0261    |
| CWSS-RR-S5  | Conventional Sounder / Beacon | 2831-CPR-F0262    |
| CWSS-RW-W5  | Conventional Sounder / Beacon | 2831-CPR-F0261    |
| CWSS-RR-W5  | Conventional Sounder / Beacon | 2831-CPR-F0262    |
| CWSS-RR-W3  | Conventional Sounder / Beacon | 2831-CPR-F0262    |
| CWSS-RB-S7  | Conventional Sounder / Beacon | 2831-CPR-F0256    |
| CWSS-RB-W7  | Conventional Sounder / Beacon | 2831-CPR-F0256    |
| DSE1-EN   | Acoustic self-powered device  | 0051-CPR-02157    |
| DSE1-PW   | Audio/Visual Device           | 1293-CPR-0600     |
| DSE2-EN   | Sounder Device                | 0051-CPR-0158     |
| DSE3-EN   | Audio/Visual Device           | 0051-CPR-0158     |
| DSE3-HQW  | Audio/Visual Device           | 1293-CPR-0570     |
| DSE3-23 HW  | Audio/Visual Device           | 1293-CPR-0570     |
| DSE3-23 HQ  | Audio/Visual Device           | 1293-CPR-0570     |
| PY X-S-05   | Visual alarm Device           | 0786-CPD-21219    |
| PY X-S-05-CL  | Visual alarm Device           | 0786-CPD-21219    |
| PY X-M-05-CL  | Visual alarm Device           | 0786-CPD-21499    |






**The list of system compatible components (part 8):**

|  |                              |                |
|--|------------------------------|----------------|
| PY X-M-05-RED  | Visual Alarm device          | 0786-CPD-21499 |
| PY X-M-10  | Visual Alarm device          | 0786-CPD-21499 |
| PY X-M-10-CL   | Visual Alarm device          | 0786-CPR-21499 |
| PA 5   | Sounder Alarm device         | 0786-CPD-21182 |
| PA 5-GREY  | Sounder Alarm device         | 0786-CPD-21182 |
| PA 10  | Sounder Alarm device         | 0786-CPD-21223 |
| PA 10-GREY   | Sounder Alarm device         | 0786-CPD-21223 |
| PA 20  | Sounder Alarm device         | 0786-CPD-21223 |
| PA 20-GREY   | Sounder Alarm device         | 0786-CPD-21223 |
| PA X 1-05  | Visual/Acoustic Alarm device | 0786-CPD-21220 |
| PA X 1-05-CL   | Visual/Acoustic Alarm device | 0786-CPD-21220 |
| QUADRO F12-3G/3D                                       | Visual/Acoustic Alarm device | PDG 04.0002 X  |
| DS 10 -3G/3D   | Visual/Acoustic Alarm device | 0786-CPD-20005 |
| BEXs 110D-C  | Sounder Alarm device         | G 209081       |
| BEXDS 120D-C   | Sounder Alarm device         | G 209081       |
| IS-mC1   | Combined Sounder / Beacon    | 0786-CPD-20338 |
| PAN1-PLUS-W  | Audio/Visual Device          | 1293-CPR-0597  |
| PAN1-PLUS-Y  | Audio/Visual Device          | 1293-CPR-0597  |
| PAN1-PLUS-EN3  | Sounder Device               | 1293-CPR-0602  |
| <b>Door holders connected by Output Module</b>         |                              |                |
| 960120   | Door Holder                  | Nr.0150-CPR    |
| 960119   | Door Holder                  | Nr.0143-CPR    |
| 960121   | Door Holder                  | Nr.0152-CPR    |
| 960122   | Door Holder                  | Nr.0153-CPR    |
| 960130   | Door Holder                  | Nr.0017-CPR    |
| UTKFM05  | Door Holder                  | 0407-CPD-056   |
| UTKFM10  | Door Holder                  | 0407-CPD-056   |
| UTKFZ05C   | Door Holder                  | 0407-CPD-056   |
| UTKFZ05L   | Door Holder                  | 0407-CPD-056   |
| <b>Conventional aspiration system via Input module</b> |                              |                |
| VLF-250-01   | Aspiration System            | 0832-CPR-F1223 |
| VLF-500-01   | Aspiration System            | 0832-CPR-F1223 |
| VELU-A00   | Aspiration System            | 0786-CPR-21347 |
| VEU-A10  | Aspiration System            | 0786-CPR-21347 |
| VEP-A00-P  | Aspiration System            | 0786-CPR-21346 |
| VEP-A10-P  | Aspiration System            | 0786-CPR-21346 |
| VEP-A00-1P   | Aspiration System            | 0786-CPR-21346 |
| VES-A00-P  | Aspiration System            | 0786-CPR-21346 |



The list of system compatible components (part 9):

|   |                            |                   |
|---|----------------------------|-------------------|
| VES-A10-P   | Aspiration System          | 0786-CPR-21346    |
| VEA-040-A00   | Aspiration System          | 0786-CPR-21537    |
| VEA-040-A10   | Aspiration System          | 0786-CPR-21537    |
| VER-A40-40-STX                                      | Aspiration System          | 0786-CPR-21537    |
| VLI-880   | Aspiration System          | 0832-CPR-F0259    |
| VLI-885   | Aspiration System          | 0832-CPR-F0259    |
| FLX-010   | Aspiration System          | 0786-CPR-21734    |
| FLX-020   | Aspiration System          | 0786-CPR-21734    |
| <b>Remote Power Supply for conventional devices</b> |                            |                   |
| HLSPS25   | Power supply equipment     | 1134-CPR-085      |
| ALI50EN   | Power supply equipment     | 1293-CPR-0483     |
| HLSPS50   | Power supply equipment     | 1134-CPR-085      |
| EFC-PS524   | Power supply equipment     | 1293-CPR-0603     |
| VPS-250-E5  | Power supply equipment     | G 220018          |
| <b>Digital communicator</b>                         |                            |                   |
| DAL-COM21   | Digital Communicator IP/4G | 2531-CPR-232.1747 |



*(Handwritten signature in blue ink)*